

From: Kowalski, Richard [mailto:Rick.Kowalski@arcadis-us.com]

Sent: Tuesday, June 03, 2014 9:56 AM

To: Crawford, Jeffrey (DEM)

Cc: Pallister, Donna

Subject: RE: Springfield Street report

We are scheduled to complete site monitoring next week. The CO2 exceedances were in the Middle school gym and the elementary school elevator, so these readings may have been due to timing of the readings relative to high occupancy occurrences for these facilities. We will evaluate the new data immediately and advise you if any actions are needed.

Richard G. Kowalski, CPG, LSP, CHMM
ARCADIS U.S., Inc