



Public Record – Summary Information On Motor Fuel Underground Storage Tanks (USTs)

Public Record Posted Date: 10/01/2009

General Information

Total Number of Active Federal UST Facilities:..... 620
 Total Number of Active Federal USTs:..... 1593
 Total Number of Active and Inactive Federal Leaking UST (LUST) Cases:..... 1,324
 Total Number of Active Federal LUST Cases:..... 225

Summary Information for On-Site Inspections

Number of UST Facilities Inspected:..... 190
 Inspection Period Dates: October 1, 2008 to: September 30, 2009

Release Prevention Compliant:..... 87.9%
 Release Detection Compliant:..... 73.2%
 Percent Compliance (Combined Measure):..... 70.5%

Note: Tank, facility, and on-site inspection information is based on inspections of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with [State of Rhode Island](#) and [U.S. EPA](#) regulations governing the prevention and detection of petroleum releases or discharges from underground storage tanks.

Summary Information for Releases

Number of Confirmed UST Releases:..... 4
 Release Reporting Period Dates: October 1, 2008 to: September 30, 2009

Summary Information for Release Sources and Causes - New Federal LUST Cases															
Source			Cause												
			Spill/ Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other**		Unknown		
		%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	2	50%					1	50%						1	50%
Piping	0	0%													
Dispenser	0	0%													
STP	0	0%													
Delivery Problem	0	0%													
Unknown	2	50%												2	100%
Other*	0	0%													
Totals	4	100%					1							3	

= number
 % = percent of releases by source *or* percent of causes by source
 * low level contamination, not expected to be a continuing release from UST system
 ** cause is known but does not fit into other categories

Note: Source and cause data were compiled from data collected during the investigation of UST system releases such as new Federal LUST Cases.

If you have questions pertaining to any of the information provided above, please contact:
Jason Proulx (Phone 401-222-4700 ext. 7137; jason.proulx@dem.ri.gov) or
Sofia Kaczor (Phone 401-222-4700 ext. 7121; sofia.kaczor@dem.ri.gov.)

Public Record page was created and data was compiled by Lacey Anderson - 2009 Summer Technical Support.