



Public Record – Summary Information On Motor Fuel Underground Storage Tanks (USTs)

Public Record Posted Date: 10/01/2017

General Information

Total Number of Active Federal UST Facilities:..... 543
 Total Number of Active Federal USTs:..... 1475
 Total Number of Active and Inactive Federal Leaking UST (LUST) Cases:..... 1420
 Total Number of Active Federal LUST Cases:..... 152

Summary Information for On-Site Inspections

Number of UST Facilities Inspected:..... 233
 Inspection Period Dates: October 1, 2016 to: September 30, 2017

Release Prevention Compliant:..... 64%
 Release Detection Compliant:..... 50%
 Percent Compliance (Combined Measure):..... 43%

Note: Tank, facility, and on-site inspection information is based on inspections of UST motor fuel facilities only; heating oil USTs are not included. On-site inspections measure compliance with [State of Rhode Island](#) and [U.S. EPA](#) regulations governing the prevention and detection of petroleum releases or discharges from underground storage tanks.

Summary Information for Releases

Number of Confirmed UST Releases:..... 13
 Release Reporting Period Dates: October 1, 2016 to: September 30, 2017

Summary Information for Release Sources and Causes - New Federal LUST Cases														
Source			Cause											
			Spill/ Overfill		Phy/Mech Damage		Corrosion		Install Problem		Other**		Unknown	
		%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	3	23%					3	100%					0	0%
Piping	1	8%											1	100%
Dispenser	2	15%											2	100%
STP	0	0%											0	0%
Delivery Problem	0	0%											0	0%
Unknown	5	38%											5	100%
Other*	2	15%	2	100%									0	0%
Totals	13	100%	2	15%			3	23%					8	62%

= number
 % = percent of releases by source *or* percent of causes by source
 * low level contamination, not expected to be a continuing release from UST system
 ** cause is known but does not fit into other categories

Note: Source and cause data were compiled from data collected during the investigation of UST system releases such as new Federal LUST Cases.

For site specific information, please contact:
 Sofia Kaczor (Phone 401-222-4700 ext. 7121; sofia.kaczor@dem.ri.gov.)