

From: Pallister, Donna [mailto:Donna.Pallister@lfr.com]

Sent: Thursday, May 07, 2009 8:40 AM

To: Jeffrey Crawford

Cc: Alan Sepe; Tremblay, Stephen

Subject: Springfield Street Schools

Jeff,

During the quarterly monitoring we found that 2 blowers, one at Carnevale Elementary School and one at Del Sesto Middle, are not operating. Each building has one operational blower. One blower appears to have a malfunctioning sensor that may need to be replaced, and we have not determined the problem at the other blower. We have scheduled an electrician to inspect the blowers and assist in identifying the problems. We did not detect any concentrations above the action levels in either building during the monitoring.

We will determine what needs to be done to repair the blowers and keep you informed.

Thank you,

Donna

Donna Holden Pallister, PE, LSP
Senior Engineer
LFR Inc. an Arcadis Company
300 Metro Center Boulevard, Suite 250
Warwick, RI 02886-1751
main: 401-738-3887
cell: 401-255-9619
fax: 401-732-1686
www.lfr.com