

**From:** Donna Pallister [donna.pallister@lfr.com]  
**Sent:** Thursday, May 17, 2007 2:35 PM  
**To:** Jeffrey Crawford  
**Cc:** 'Tremblay, Stephen'; 'Alan Sepe'  
**Subject:** Sub-slab ventilation system at Springfield Street Middle School  
Jeff,

I am sending this e-mail as a follow-up to my phone notification yesterday regarding one of the blowers for the sub slab ventilation system at Springfield Street Middle School. While on-site yesterday I discovered that the blower in the front shed was off because water had collected in the knockout tank to the level that caused the system to automatically shut down.

The regular quarterly indoor air monitoring was conducted and no exceedances of the Remedial Action levels were found in indoor air.

We plan to drain the water tank and restart the system tomorrow.

Donna H. Pallister, P.E., L.S.P.  
Senior Engineer  
LFR  
300 Metro Center Boulevard  
Suite 250  
Warwick, RI 02886-1751  
401-738-3887 Office  
401-255-9619 Mobile  
401-732-1686 Facsimile  
[donna.pallister@lfr.com](mailto:donna.pallister@lfr.com)  
Visit us at [www.lfr.com](http://www.lfr.com)

This message (including any attachments) is intended only for the use of the named a may contain information that is legally privileged, confidential or exempt from disc If you are not a named addressee, you are hereby notified that any use, disseminatio of this message is strictly prohibited. If you have received this message in error, sender immediately by telephone or by return e-mail and delete this message, along w from your computer. Thank you.